

Certificate of Conformity

Certificate Number: CN-PV-200054

On the basis of the tests undertaken, the samples of the below product have been found to comply with the requirements of the referenced specifications /standards at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture. The manufacturer shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

Applicant Name & Address:	Shenzhen Growatt New Energy Technology CO.,Ltd 1st East & 3rd Floor of Building A, Building B, Jiayu Industrial Park, #28, GuangHui Road, LongTeng Community, Shiyan Street, Baoan District, Shenzhen, P.R.China
Product Description:	PV Grid inverter
Ratings & Principle Characteristics:	See Annex to Certificate of Conformity
Models/Type References:	Growatt 3000 TL3-S, Growatt 4000 TL3-S, Growatt 5000 TL3-S, Growatt 6000 TL3-S, Growatt 7000 TL3-S, Growatt 8000 TL3-S, Growatt 9000 TL3-S, Growatt 10000 TL3-S, Growatt 11000 TL3-S
Brand Name:	Growatt
Specification/Standard:	TOR Erzeuger Typ A Version 1.0:1.8.2019 OVE-Richtlinie R 25:2020-03-01 Connection and parallel operation of power generation plants of type A and of small generation plants (maximum capacity <250 kW and nominal voltage <110 kV)
Certificate Issuing Office Name & Address:	Intertek Testing Services Ltd. Shanghai 2/F (West Side), No. 707, Zhangyang Road, Free Trade Experimental Area, Shanghai, P. R. China
Test Report Number:	200109114GZU-001, Revision 1

Additional information in Appendix.



Signature

Certification Manager: Grady Ye

Date: 19 June 2020

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-200054

Ratings &
Principle
Characteristics:

MODEL	Growatt 8000 TL3-S	Growatt 9000 TL3-S	Growatt 10000 TL3-S	Growatt 11000 TL3-S	Growatt 7000 TL3-S
Max PV voltage	1000Vdc				
Voltage range	160-1000Vdc				
MPPT voltage	360-850	400-850	450-850		320-850
PV Isc	16A/16A				
Max power	8.8KVA	9.9KVA	11.0KVA	12.1KVA	7.7KVA
Max output current	3*13.3A	3*15A	3*16.7A	3*18.3A	3*11.7A
Output voltage	3W/N/PE 230Vac/400Vac				
Nominal Frequency	50Hz				
Power Factor	0.8 Leading to 0.8 Lagging				
Ambient Temperature	-25°C - +60°C				
Protection Degree	IP65				
Protection Class	Class I				
Software Version	dhaa0101				

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-200054

Ratings &
Principle
Characteristics:

MODEL	Growatt 3000 TL3-S	Growatt 4000 TL3-S	Growatt 5000 TL3-S	Growatt 6000 TL3-S
Max PV voltage	1000Vdc			
Voltage range	140-1000Vdc			
MPPT voltage	160-800	200-800	250-800	290-800
PV Isc	16A/16A			
Max power	3.0KVA	4.0KVA	5.0KVA	6.0KVA
Max output current	3*4.5A	3*6.1A	3*7.6A	3*9.1A
Output voltage	3W/N/PE 230Vac/400Vac			
Nominal Frequency	50Hz			
Power Factor	0.8 Leading to 0.8 Lagging			
Ambient Temperature	-25°C - +60°C			
Protection Degree	IP65			
Protection Class	Class I			
Software Version	dhaa0101			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.